

FACTORY MUTUAL



Factory Mutual Research Corporation
1151 Boston Providence Turnpike
P.O. Box 9102
Norwood, Massachusetts 02062
Telephone: (781) 762-4300
Fax: (781) 762-9375

SERIAL NO. OD1F9.CY

July 14, 1997

**FLAMMABILITY TESTING
ON A
LIQUID PRODUCT SAMPLE
FOR ENVIRO TECH INTERNATIONAL, INC.
2525 W. LEMOYNE AVE.
MELROSE PARK, IL 60160**

INTRODUCTION

Enviro Tech International, Inc. has requested that testing be performed on a liquid product sample.

SAMPLE IDENTIFICATION

The sample was identified as Ensolv.

TEST REQUIRED

The closed and open cup flash points for the submitted sample were requested per Purchase Order No. PO 70812.

TEST RESULTS

Closed Cup Flash Point

No flash point could be attained for this sample up to its boiling point temperature of 156 oF using the Tagliabue Closed Cup Flash Point equipment in accordance with the ASTM D-56 test method. Flame enlargement was observed up to this temperature.

Open Cup Flash and Fire Point

No flash or fire point was developed for this sample up to its boiling point temperature of 156 oF using the Cleveland Open Cup Flash Point equipment in accordance with the ASTM D-92 test method. Flame enlargement was again observed up to this temperature.

Tests by: R.C. Merritt, P.E.

Report by: D.W. Lewin